


**NOTE:**

1. FIELD WIRING TERMINAL: [ # ]

**TERMINAL CONNECTIONS FOR REMOTE CONTROL:**

CW	120VAC CW TO NEUTRAL
CCW	120VAC CCW TO NEUTRAL
STOP	NONE



17-3011-010 -

SIZE:  
**A**

THIS DOCUMENT IS A COPY AND IS NOT THE SOURCE DOCUMENT. INFORMATION IS SUBJECT TO CHANGE WITHOUT NOTICE. THE INFORMATION CONTAINED HEREIN IS COPYRIGHTED BY HAROLD BECK AND SONS, INC. CHANGES TO THE DOCUMENT ARE PROHIBITED. CONTACT A BECK SALES ENGINEER IF A CERTIFIED DRAWING IS REQUIRED.

## HAROLD BECK & SONS INC

NEWTOWN INDUSTRIAL COMMONS NEWTOWN, PENNSYLVANIA 18940 USA

TITLE:

WIRING DIAGRAM GROUP 31 OPTION 1  
120 VOLT 2 AUX SWITCHES PULSED AC  
5X20 FUSE

DRAWN:  
GMD 12/9/15

SCALE:  
NONE

DRAWING NO:

REV:

CHECKED:  
BDP 12/10/15

**17-3011-010**

-

APPROVED:  
FWB 1/19/16

SHEET NO. 1 OF 1